



GENERAL NOTES:

- A. CONCEALED CABLE TRAY INSTALLED ABOVE CEILING TILE DOES NOT REQUIRE BOTTOM TRAY AND TOP COVER FITTINGS. PROVIDE TRAY AND COVER FOR EXPOSED CABLE TRAY ONLY.
- B. SUPPORT CABLES FROM CABLE TRAY TO 1" CONDUIT STUB OF OUTLET BOX WITH J-HOOKS ABOVE SUSPENDED CEILING. INSTALL J-HOOKS ON 48" CENTERS.
- C. PROVIDE MINIMUM OF 1" SLEEVED PENETRATION OF WALLS EXTENDING TO OVERHEAD STRUCTURE WHERE REQUIRED FOR ROUTING CABLE TO OUTLET BOXES. PROVIDE 1" SLEEVE FOR EACH OUTLET BOX SERVED.
- D. WORK OF DIVISIONS 27 AND 28 IS SHOWN ON THIS DRAWING.

SHEET NOTES:

1. OUTLETS FOR HORIZONTAL COMMUNICATIONS CABLEING TO WORK AREA. DOUBLE GANG BOX WITH SINGLE GANG MUD RING AND 1" CONDUIT STUB UP TO ACCESSIBLE VOID ABOVE CEILING. 3 CAT-6 CABLES FROM TELECOMMUNICATIONS ROOM G07.
2. 4-4" CONDUIT SLEEVES FOR COMMUNICATIONS CABLES THROUGH FLOOR EXTENDING TO 4" ABOVE SUSPENDED CEILING. BOND TO SLEEVES THROUGH WALL. FIRESTOP FLOOR PENETRATION AND BOTH ENDS OF SLEEVES.
3. EXTEND CABLE TRAY TO WALL AND FASTEN WITH MANUFACTURER'S FITTINGS.
4. 2-4" CONDUITS FOR COMMUNICATIONS THROUGH WALL. BOND TO TRAY AND FIRESTOP WALL PENETRATIONS AND BOTH ENDS OF SLEEVES.
5. 12" WIDE X 2" HIGH WIRE MESH CABLE TRAY ABOVE SUSPENDED CEILING. PROVIDE DIAGONAL SUPPORTS AS REQUIRED TO RESTRICT LATERAL SWAY.
6. FORM CORNERS AND SPLICES PER MANUFACTURER'S INSTRUCTIONS.
7. OUTLET FOR WALL MOUNTED TELEPHONE AT 48" A.F.F. OWNER TO PROVIDE INSTRUMENT. PROVIDE 1 CAT-6 CABLE AND INSTALL WALL PHONE FACE PLATE.
8. FLUSH MOUNT OUTLETS UNDER COUNTER IN FRAME WALL.
9. PROVIDE DURESS ON UNDERSIDE OF COUNTER WITHIN REACH OF SEATED PERSON AT COUNTER. CABLE TO PANEL IN ROOM G07.

FIRST FLOOR 1 TELECOMMUNICATIONS PLAN

0' 4' 8' 12' 16' 20' 24' SCALE: 1/4" = 1'-0"

95% SUBMISSION

CSHQ&A

C.W. MOORE PLAZA
250 S. 6TH ST. - BOISE, ID 83702
(208) 343-4635 - FAX (208) 343-1858
http://www.cshqa.com

AMY E. DOCKTER, P.E.
C.W. MOORE PLAZA
250 S. 6TH ST.
BOISE, IDAHO
PHONE: 208-343-4635 FAX: 208-343-1858

THESE DRAWINGS AND SPECIFICATIONS, AS INSTRUMENTS OF SERVICE, ARE AND SHALL REMAIN THE PROPERTY OF THE ARCHITECT / ENGINEER. NO PART OF THESE DRAWINGS OR SPECIFICATIONS SHALL BE REPRODUCED OR USED IN ANY MANNER OR FOR ANY OTHER PROJECTS WITHOUT THE WRITTEN CONSENT OF CSHQA OR ITS AFFILIATES. Copyright 1991

PRELIMINARY
NOT FOR
CONSTRUCTION

DRAWING TITLE
FIRST FLOOR
TELECOMMUNICATIONS PLAN

APPROVED: DIVISION CHIEF

APPROVED: SERVICE DIRECTOR

PROJECT TITLE
VAMC
RENOVATE
BUILDING 33

BUILDING NUMBER
33

CHECKED
AKD

DRAWN
JDR

LOCATION
BOISE, IDAHO

DATE
03/04/11

PROJECT NO.
531-10-114

DRAWING NO.
E2.9

DWG. 90 OF 102

